


NOTES: DETAIL DESIGNED TO ACCOMMODATE MAX. 50% TOTAL MOVEMENT.
 BACKER ROD AND SEALANT ARE REQUIRED IN JOINT PRIOR TO MM 6125/
 FLEX-FLASH UN INSTALLATION.
 IN COVERED/BURIED CONDITIONS, MM 6125 IS EXTENDED AS CONTINUOUS
 FLASHING AS HIGH AS POSSIBLE. FLASHING MUST BE TERMINATED NO LESS
 THAN 4" ABOVE SUBSTRATE. IN ADDITION, ADEQUATE PROTECTION MUST BE
 PROVIDED FOR FLASHING FROM SUBSEQUENT TOPPING/BACKFILL. (SEE W-6B)
 WHENEVER POSSIBLE THE EXPANSION JOINT SHOULD BE EXTENDED UP
 THROUGH ALL TOPPING LAYERS.
 REGLETS CAN BE CAST/FORMED OR CUT INTO THE CONCRETE. REGLETS
 SHOULD BE MIN. 1/2" DEEP AND PROVIDE AN EASY TRANSITION FOR THE
 MEMBRANE FLASHING.



Monolithic
Membrane
6125-FR
WATERPROOFING SYSTEMS

AMERICAN HYDROTECH, INC.

EXPANSION JOINTS
UP TO 1" AS-BUILT WIDTH

3"=1'-0"	W-6A
----------	------